

Section 01575

STABILIZED CONSTRUCTION EXIT

PART 1 GENERAL

1.01 SUMMARY

This Section includes the installation of erosion and sediment control for stabilized construction exits used during construction and prior to final development of site.

1.02 MEASUREMENT AND PAYMENT

Measure and pay for stabilized construction roads, parking areas, exits and truck washing area by square yard of aggregate placed in 8-inch layer. No separate payment shall be made for Street Cleaning as required by NPDES. Include cost of Work for Street Cleaning under Section in pay items for which Work is a component. No separate payment shall be made for repair or replacement of stabilized construction exits.

1.03 REFERENCES

ASTM D 4632/D 4632M Rev A - Standard Test Method for Grab Breaking Load and Elongation of Geotextiles.

1.04 SUBMITTALS

- A. Conform to requirements of Section 01330 – “Submittal Procedures”.
- B. Submit manufacturer’s catalog sheets and other product data on geotextile fabric.
- C. Submit sieve analysis of aggregates conforming to requirements of this Specification.

1.05 RELATED REQUIREMENTS

Section 01330 – “Submittal Procedures”

1.06 – 1.13 NOT USED

PART 2 PRODUCTS

2.01 MANUFACTURER(S) (NOT USED)

2.02 MATERIALS AND/OR EQUIPMENT

- A. Geotextile Fabric

1. Provide woven or non-woven geotextile fabric made of polypropylene, polyethylene, ethylene, or polyamide material.
2. Geotextile fabric shall have minimum grab strength of 270 psi in any principal direction (ASTM D 4632/D 4632M Rev A) and equivalent opening size between 50 and 140.
3. Geotextile and threads shall be resistant to chemical attack, mildew, and rot and shall contain ultraviolet ray inhibitors and stabilizers to provide minimum of 6 months of expected usable life at temperature range of 0°F to 120°F.

B. Coarse Aggregates

1. Coarse aggregate shall consist of crushed stone, gravel, crushed blast furnace slag, or combination of these materials. Aggregate shall be composed of clean, hard, durable materials free from steel reinforcement material, adherent coatings, salt, alkali, dirt, clay, loam, shale, soft or flaky materials, or organic and injurious matter.
2. Coarse aggregates shall conform to following gradation requirements.

Sieve Size	Percent Retained
(Square Mesh)	(By Weight)
2-1/2"	0
2"	0 - 20
1-1/2"	15 - 50
3/4"	60 - 80
No. 4	95 - 100

2.03 – 2.04 NOT USED

PART 3 EXECUTION

3.01 – 3.02 NOT USED

3.03 ERECTION/INSTALLATION APPLICATION AND/OR CONSTRUCTION

A. Preparation and Installation

1. If necessary to keep street clean of mud carried by construction vehicles and equipment, provide stabilized construction roads and exits at construction, staging, parking, storage, and disposal areas. Construct erosion and sediment controls in accordance with requirements shown on Plans and specified in this Section.

2. No clearing, grubbing or rough cutting permitted until erosion and sediment control systems are in place, other than as specifically directed by Project Manager to allow soil testing and surveying.
3. Maintain existing erosion and sediment control systems located within Project site until acceptance of Project or until directed by Project Manager to remove and discard existing system.
4. Regularly inspect, maintain, repair, or replace components of stabilized construction exits. Unless otherwise directed, maintain stabilized construction roads and exits until project is accepted by the Owner. Remove stabilized construction roads and exits promptly when directed by Project Manager. Discard removed materials off site.
5. Remove and dispose of sediment deposits at designated spoil site for Project. If project spoil site is not designated on Plans, dispose of sediment off site at location not in or adjacent to stream or flood plain. Assume responsibility for offsite disposal. Spread sediment evenly throughout site, compacted and stabilized. Do not allow sediment to flush into stream or drainage way. If sediment has been contaminated, dispose in accordance with existing federal, state, and local rules and regulations.
6. Prohibit equipment and vehicles from maneuvering on areas outside of dedicated rights-of-way and easements for construction. Immediately repair damage caused by construction traffic to erosion and sediment control systems.
7. Conduct construction operation under this Contract in conformance with erosion control practices.

B. Construction Methods

1. Provide stabilized access roads, subdivision roads, parking areas, and other on-site vehicle transportation routes where shown on Plans.
2. Provide stabilized construction exits and truck washing areas when approved by Project Manager, of sizes and locations where shown on Plans or as specified in this Section.
3. Vehicles leaving construction areas shall have their tires cleaned to remove sediment prior to entrance onto public right-of-way. When washing is needed to remove sediment, construct truck washing area. Truck washing shall be done on stabilized areas which drain into drainage system protected by erosion and sediment control measures.
4. Details for stabilized construction exit are shown on Plans. Construct other stabilized areas to same requirements. Maintain roadway width at least 14 feet

for one-way traffic and 20 feet for two-way traffic and sufficiently for ingress and egress. Furnish and place geotextile fabric as permeable separator to prevent mixing of coarse aggregate with underlying soil. Maximum exposure of geotextile fabric to elements between laydown and cover of 14 days to minimize damage potential.

5. Grade roads and parking areas to provide sufficient drainage away from stabilized areas. Use sandbags, gravel, boards, or similar methods to prevent sediment from entering public right-of-way, receiving stream or storm water conveyance system.
6. Inspect and maintain stabilized areas daily. Provide periodic top dressing with additional coarse aggregates to maintain required depth. Repair and clean out damaged control measures used to trap sediment. Immediately remove sediment spilled, dropped, washed, or tracked onto public right-of-way.
7. Maintain length of stabilized area as shown on Plans, but not less than 50 feet. Maintain thickness less than 8 inches. Maintain width less than full width of all points of ingress or egress.
8. Stabilization for other areas shall have same coarse aggregate, thickness, and width requirements as stabilized construction exit, except where shown otherwise on Plans.
9. Stabilized area may be widened or lengthened to accommodate truck washing area when authorized by Project Manager.
10. Alternative methods of construction may be utilized when shown on Plans, or when approved by Project Manager.
11. Provide street cleaning, such as sweeping or vacuuming, at locations around project site where construction traffic has caused tracking of sediments onto roadways. Do not wash or flush sediments into adjacent drainage systems.
12. Mechanical sweepers shall be vacuum-type or regenerative sweepers. Sweeping speed not to exceed 6 mph. Make two passes.
13. Clean street daily before end of workday. When excess sediments have tracked onto streets, Project Manager may direct contractor to clean street as often as necessary. Remove and dispose of sediments properly.
14. Use other erosion and sediment control measures to prevent sediment runoff during period of rains and non-working hours and when storm discharges are expected.

3.04 – 3.10 NOT USED

END OF SECTION