

Section 02911

TOPSOIL

PART 1 GENERAL

1.01 SUMMARY

This Section includes furnishing and placing topsoil for finish grading and for seeding, sodding, and planting.

1.02 MEASUREMENT AND PAYMENT

A. Unit Prices.

1. No separate payment will be made for topsoil under this Section. Include payment in Section 02921 – “Hydromulch Seeding” or Section 02922 – “Sodding”.
2. Refer to Section 01270 – “Measurement and Payment” for unit price procedures.

B. Stipulated Price (Lump Sum). If Contract is Stipulated Price Contract, payment for Work in this Section is included in total Stipulated Price.

1.03 – 1.04 NOT USED

1.05 RELATED REQUIREMENTS

- A. Section 01270 – “Measurement and Payment”
- B. Section 01576 – “Waste Material Disposal”
- C. Section 02315 – “Roadway Excavation”
- D. Section 02320 – “Utility Backfill Materials”
- E. Section 02921 – “Hydromulch Seeding”
- F. Section 02922 – “Sodding”

1.06 – 1.13 NOT USED

PART 2 PRODUCTS

2.01 MANUFACTURER(S) (NOT USED)

2.02 MATERIALS AND/OR EQUIPMENT

A. Topsoil

1. Topsoil shall be fertile, friable, natural sandy loam surface soil obtained from excavation or borrow operations having following characteristics:
 - a. pH value of between 5.5 and 6.5
 - b. Liquid limit: 50 or less
 - c. Plasticity index: 20 or less
 - d. Gradation: maximum of 10 percent passing No. 200 sieve
2. Topsoil shall be reasonably free of subsoil, clay lumps, weeds, non-soil materials, and other litter or contamination. Topsoil shall not contain roots, stumps, and stones larger than 2 inches.
3. Obtain topsoil from naturally well-drained areas where topsoil occurs at minimum depth of 4 inches and has similar characteristics to that found at placement site. Do not obtain topsoil from areas infected with growth of, or reproductive parts of nut grass or other noxious weeds.

2.03 – 2.04 NOT USED

PART 3 EXECUTION

3.01 GENERAL / MANUFACTURER(S) (NOT USED)

3.02 PREPARATION

A. Examination

1. Excavate topsoil for esplanades and areas to receive grass or landscaping from areas to be further excavated. Stockpile in area approved by Project Manager.
2. Stockpile topsoil to depth not exceeding 8 feet. Cover to protect from erosion

3.03 ERECTION/INSTALLATION APPLICATION AND/OR CONSTRUCTION

A. Topsoil Excavation

Conform to excavation and stockpiling requirements of Section 02315 – “Roadway Excavation”.

B. Placement

1. Place no topsoil until subgrade has been approved. For areas to be seeded or sodded, scarify or plow existing material to minimum depth of 4 inches, or as indicated on Plans. Remove vegetation and foreign inorganic material. Place 4 inches of topsoil on loosened material and roll lightly with appropriate lawn roller to consolidate topsoil.
2. Increase depth of topsoil to 6 inches when placed over sand bedding and backfill materials specified in Section 02320 – “Utility Backfill Material”.
3. For areas to receive shrubs or trees, excavate existing material and place topsoil to depth and dimensions shown on Plans.
4. Remove spilled topsoil from curbs, gutters, and, paved areas and dispose of excess topsoil in accordance with requirements of Section 01576 – “Waste Material Disposal”.
5. Place topsoil to promote good drainage and compact with light roller. Water topsoil after placement until saturated for minimum depth 6 inches, fill in, and recompact areas of settlement.

3.04 – 3.08 NOT USED

3.09 PROTECTION

Protect topsoil from wind and water erosion until planting is completed.

3.10 SCHEDULES (NOT USED)

END OF SECTION